



<b>LEGEND</b>	A) 132KV LINE		METER INSTALLED	
	B) 66KV LINE		METER NOT INSTALLED	
	C) CONDUCTOR	66KV line ACSR DOG conductor 132KV line ACSR PANTHER conductor except Khowai-Kamalpur (32KM) in 2 <sup>ND</sup> fdr. & Champaknagar-Teliamura (15KM) IN 1 <sup>ST</sup> fdr. – Alloy conductor.		
	<b>Proposed Capacity/Sub-Station addition</b>	Proposed Line :		66 KV
			132 KV	
			220 KV	
			400 KV	

<b>Tripura State Electricity Corporation Limited</b>	SHEET NO		
	1 OF 1	DRAWN	A. Bhowmik
	S.L. DIAGRAM OF EXISTING AND PROPOSED POWER NETWORK OF TRIPURA AT 132/66/220(P) KV SUB-STATIONS		CHECKED
		APPROVED	M. Debbarma